CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7170-1130:235 Page 1 of 2

CATEGORY: Control Unit (High-Rise)

LISTEE: Honeywell International Inc. 1500 W. Dundee Road, Arlington Heights, IL 60004-1472

Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

DESIGN: Model XLS140 and XLS140E fire alarm control units. Local, auxiliary, remote station (PPU),

proprietary (PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and

operational considerations. System components:

XLS140-CPU/-140ECPU CPU Board

XLS-NCA Network Communication Annunicator

NCM-W/F Network Control Module
LEM-320 Loop Expander Module
KDM-2 Keyboard Display Module
TM-4 Transmitter Module

XLS-CAB-4 Series Enclosure TR-A4, -B4, -C4, -D4 Trim Ring

DP-DISP Display Dress Panel

DP-1B Blank Panel

DPI-232 Direct Panel Interface

BMP-1 Blank Module
XPDP, DPDW-1B, DPSW-1B, VP-2B Dress Panels
CHS-4MB, -M2, -4L, -4N Chassis
XLS-LBB, BB-25, BB-17 Battery Boxes
BP-4 Battery Panel

STS-1 Security Tamper Switch
UDACT UZC-256 Universal Zone Coder
ACM-8R, -16AT, -32A, 24AT, -48A Annunciator Control Module

ACM-8R, -16A1, -32A, 24A1, -48A
ARM-16AT, AEM-32A, 24AT, -48A
ARM-16AT, AEM-32A, 24AT, -48A
ARM-16AT, AEM-32A, 24AT, -48A
Annunciator Control Module
ARM-16AT, AEM-32A, 24AT, -48A
Annunciator Control Modules
ARM-16AT, AEM-32A, 24AT, -48A
Annunciator Control Modules
ARM-16AT, AEM-32A, 24AT, -48A
Annunciator Expander Modules
ARM-16AT, AFM-32A
Annunciator Fixed Modules
Annunciator Key Switch

RPT-W, RPT-485W, RPT-485WF

RPT-F

SCS-8

Smoke Control Station

SCE-8

Repeater Wire

Repeater Fiber

Smoke Control Station

Smoke Control Expander

SCS-8L Smoke Control Lamp Driver Station SCE-8L Smoke Control Expander Lamp

Liquid Crystal Display

LDM-32, -E32, -R32

RA400, -400Z, FDU-80

FFT-7, -7S

Fire Fighter's Telephone
FHS

Fireman's Handset

FPJ Fireman's Phone Jack
RPJ-1 Remote Fireman's Phone Jack

VCM-4RK Voice Control Module
VCE-4 Voice Control Expander
ARM-4 Auxiliary Relay Module
AMG-1, -E Audio Message Generator

AA-30, -100, -120 Amplifiers

XLS-LCD-80

ABF-1B,-1DB,-2B,-2DB,-4B,-4DB
Annunciator Enclosures
ABS-1TB, -2B
Annunciator Surface Box
APS-6R/APS-6RE
Auxiliary Power supply

ACPS-2406 Addressable Power Supply & Battery Charger

CHG-120 Battery Charger

FCPS-24 Field Charger/Power Supply DCM-4RK Dual Channel Module CCM-1 Communication Module CRM-4RK Control Relay Module CRE-4 Control Relay Expander ICM-4RK Indicating Control Expander ICE-4 Indicating Circuit Expander

XP5-M, XP5-C Transponder

XPIQ Transponder Quad Intelligent Audio

XPC-8 Transponder Control Module
XPM-8, XPM-8L Transponder Monitor Modules
XPP-1 Transponder Processor
XPR-8 Transponder Relay Module

PRN-5 Printer

VS4095 Keltron Remote Printer CRT-2 Display Terminal

ACT-1, -2 Audio Coupling Transformer

RM-1, RM-1SA Remote Microphone

NBG-12LRA
REL-2.2K
Releasing Supervision Kit
*XP6-C
Supervised Control Module
*XP6-MA
Six Zone Interface Module
*XP6-R
Six Relay Control Module
*XP10-M
Ten Input Monitor Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for high rise applications for use with separately

listed compatible initiating and indicating devices.

These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer

to listee's Installation Instructions Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7170-0028:216

*Rev 1-06-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 10, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division